



No.W-11062/1/2019-EE(AWT)/5
GOVERNMENT OF MIZORAM



OFFICE OF THE EXECUTIVE ENGINEER, PHED
AIZAWL WATER TRANSMISSION DIVISION: AIZAWL: MIZORAM
Email id: eepheawt@gmail.com: Phone No. (0389)2334260

Dated Aizawl, the 13th July, 2026

NOTICE INVITING QUOTATION NO. 1 OF 2026-2027

Sealed Quotations is hereby invited by the undersigned on behalf of the Governor of Mizoram from the enlisted Contractors under PHE Department for Supply, Installation, Testing & Commissioning of 125kVA Silent DG Set at Greater Aizawl Water Supply Scheme (GAWSS) Phase-I, PHED, Lawipu, Aizawl.

The Quotation Documents may be obtained from the Office of the undersigned on all working days from 13th July 2026 to 21st July 2026 during office hours. The Bidders may submit their Quotation as per the prescribed format at ANNEXURE-I & V on or before 28th July 2026 up to 12:00Noon. The Quotation so received shall be opened on the same day at 1:00 PM in the same Office.

Sl No	Description of Item	Quantity	Rate in figure (Rs.)	Rate in words (Rs.)
1	Supply of 125 kVA Silent Diesel Generator Set complete with Control Panel, Acoustic Enclosure and all allied accessories.	1 complete set		
2	Transportation and transit insurance	1 Job		
3	Installation, Testing & Commissioning of 125 kVA Silent Diesel Generator Set complete with Control Panel, Acoustic Enclosure, foundation preparation, exhaust piping, cabling, earthing, loading and unloading with all allied accessories.	1 Job		
Grand Total:				

INSTRUCTIONS TO BIDDERS AND TERMS & CONDITIONS

1. The terms 'Quotation', 'Tender', 'Bid' have the same meaning in this Notice.
2. The quotation is invited for Supply, Installation, Testing & Commissioning of the material of standard quality as per relevant ISI/BIS standard / specifications etc.
3. Rate/Bid will be valid for a period of one year from the date of acceptance or till refixation is considered necessary by the Department.
4. The successful bidder shall supply, install, test and commission one (1) number 125 kVA Silent Diesel Generator Set complete with Diesel Engine, Alternator, Acoustic Enclosure, Foundation Bolts, Exhaust System, Earthing System, Battery and Battery Charger, Control Cables and Power Cables, all accessories required for successful commissioning.

5. Rates for all items should be quoted both in figure and in words.
6. Rate quoted should be FOR Greater Aizawl Water Supply Scheme Phase-I, Aizawl, Mizoram inclusive of all types of taxes, transportation, safe handling, loading and unloading.
7. The Bidders shall submit the Bid in a sealed envelope addressed to "The Sr. Executive Engineer PHED, Aizawl Water Transmission Division, Aizawl, Mizoram. Quotation no. and date must also be clearly inscribed on the top of the envelope. In no case, submission of Quotation by post will be accepted.
8. Bid Security:
No Earnest Money Deposit (EMD) shall be required. Bidders shall submit a Bid Securing Declaration in the prescribed format.
9. Performance Security:
5% of the contract amount will be deducted from the successful bidder on account of Performance Guarantee which may be released after 12 (twelve) months from the date of successful commissioning / or as and when satisfactorily decided by the Engineer-in-Charge on the work undertaken.
10. The quotation received after the due date & time of opening shall not be accepted.
11. If the Office is closed on the stipulated date and time of last date of submission or opening due to some unforeseen reason, quotation will be received up to and open in the next working day at the same place and time.
12. Quotation paper must be duly filled in all columns of the tender documents. No overwriting will be allowed.
13. The Quoted rate should include Maintenance of the Machine as per Manufacturer's manual and as per instructions of the Engineer-in-Charge for a period of one year since commissioning of the same or warranty period whichever is later.
14. Defects liability Period shall be 12 (twelve) months from the date of commissioning.
15. Quotationers should submit/write clearly the following information for the Item/Material:
 - a) Manufacturing Company/Trade Marks
 - b) Authorization/Acknowledgement from Manufacturer
 - c) ISI/BIS Specification No
16. Bidders shall submit the following Documents along with the Bid.
 - a) Bid Submission Form as per ANNEXURE-I
 - b) Price Bid as per ANNEXURE-II
 - c) Technical Bid Form as per ANNEXURE-III
 - d) Bid/Rate validity as per Annexure-IV
 - e) Bid Securing Declaration as per Annexure-V
 - f) Experience documents for SITC of DG Set of rating 125kVA and above as per Form I.

- g) Information about on-going similar works as per Form-II.
 - h) Any other information the Bidder desires to submit in support of their Bid.
17. Any direct or indirect canvassing by any quotations will be result in disqualification of the selected quotationer(s).
 18. Postal request for sending the documents will not be entertained.
 19. Each & every page must be signed by the quotationer including blank/back pages.
 20. The tender accepting authority or the undersigned on behalf of the tender accepting authority reserves the right to accept or reject any or all the Quotation and is not bound to accept the lowest rate.
 21. All disputes are subject to the jurisdiction of the Courts at Aizawl.
 22. The undersigned on behalf of the Governor of Mizoram, reserves the right to postpone the date of opening of tender without assigning any reason thereof.
 23. Bidder shall be entirely responsible for payment of all taxes, duties, fees, levies, applicable cess etc. during the contract period.
 24. All consumables required during testing of DG Sets at factory & site testing shall be included in the scope of the bidder.
 25. The successful bidder must provide the list of mandatory spares and consumables required for proper maintenance of the unit.
 26. The bidder shall bear all the costs and expenditure incurred and/or to be incurred by it in connection with its tender including preparation and submission of its tender and for subsequent processing of the same. Bidding documents must be submitted by hand, no submission through postal service will be entertained.
 27. The bidder shall provide in its tender the required as well as the relevant documents like technical data, literature, drawings etc. for evaluation by the procuring entity in the tender documents.
 28. If a bidder furnishes wrong and/or misleading data, statement(s) etc. about technical acceptability of the goods and services offered by it, its tender will be liable to be ignored and rejected in addition to other remedies available to the procuring entity in this regard.

29. QUALITY ASSURANCE AND MAINTENANCE:

- a) The successful bidder shall submit photocopies of the Engine Serial Number and Chassis Number, the General Arrangement Drawing (GAD), and the Manufacturer's Test Certificate certifying that the Diesel Generator Set intended for supply is brand new, has been tested, is in proper working condition, and is approved for dispatch and installation at the purchaser's site. These documents shall be submitted for approval before dispatch of the unit from the manufacturer's facility.
- b) To ensure the specified quality of work the successful bidder shall prepare a quality assurance plan. For this, successful bidder shall submit an organization chart of his technical personnel to be deployed on the work along with their qualification, job descriptions.

- c) The successful bidder shall also submit a list of tools, equipment's and the machinery and instrumentation which he proposes to use for the SITC of the machine and for testing in the field and/or in the laboratory and monitoring.
- d) The successful bidder shall prepare detailed completion shop/GA drawings. He shall also prepare and submit a maintenance manual giving procedure for maintenance, with the period of maintenance works including inspections, tools and equipment to be used, means of accessibility for all parts of the structure. He shall also include in the manual, the specifications for maintenance work that would be appropriate for his design and technique of SITC of DG Set. This manual shall be submitted within the contract period.
- e) The successful bidder shall submit detailed drawings of the Diesel Generator Set clearly indicating all major components and part names.
- f) The successful bidder shall also furnish a complete list of mandatory spare parts considered essential for the reliable operation and maintenance of the DG Set for a minimum period of three (3) years. The list of spares shall include quantities, part numbers, and manufacturer's specifications.

Note: All equipment shall conform to the latest prevailing standards.

(K. LALRINTLUANGA)
Sr. Executive Engineer PHED
Aizawl Water Transmission Division
Aizawl: Mizoram

Memo No. W-11062/1/2019-EE(AWT)/5(A) : Dated Aizawl, the 13th July, 2026


Copy to: -

1. Engineer-in-Chief, PHED for favour of information.
2. Chief Engineer, PHED, Zone-I for favour of information.
3. Superintending Engineer, PHED Aizawl WATSAN Circle for favour of information.
4. Director, Information & Public Relation Department, Govt of Mizoram for information with a request to publish the quotation in 2 (two) Local Newspaper for 2 (two) consecutive issues. A copy sample Press Quotation notice is hereby enclosed.
5. System Analyst for displaying on Department Website
6. Sub-Divisional Officer, Mechanical Sub-Division for information.
7. Office Notice Board.

Sr. Executive Engineer PHED
Aizawl Water Transmission Division



No.W-11062/1/2019-EE(AWT)/5
GOVERNMENT OF MIZORAM
OFFICE OF THE EXECUTIVE ENGINEER, PHED
AIZAWL WATER TRANSMISSION DIVISION: AIZAWL: MIZORAM



Email id: cepheawt@gmail.com; Phone No. (0389)2334260

Dated Aizawl, the 13th July, 2026

NOTICE INVITING QUOTATION NO. 1 OF 2026-2027

Sealed Quotations is hereby invited on behalf of the Governor of Mizoram by the undersigned from competent firms for SITC of 125kVA Silent Diesel Generator Set. The Quotationers should submit the rate with necessary documents conforming to IS Specification and Manufacturers. Quotations will be received upto 12:00 Noon of 28th July 2026 and will be opened on the same date at 1:00PM. Details may be collected from office of the undersigned on all working days.

(K. LALRINTLUANGA)
Sr. Executive Engineer, PHED
Aizawl Water Transmission Division
Aizawl : Mizoram

FORM OF BID SUBMISSION
(Quotation No. 1 of 2026 – 2027, Dated 13th July 2026)
(Aizawl Water Transmission Division, PHED)

To,

The Executive Engineer PHED
Aizawl Water Transmission Division,
Aizawl : Mizoram

Sir,

I/We, the undersigned, declare that:

1. I/We have examined the NIQ and have no reservations to the Quotation Document.
2. I/We offer to execute the Works so described and also remedy on any defects therein in conformity with the Conditions of the Quotation and Specifications at our quoted rates.
3. We understand that you are not bound to accept the lowest or any tender you may receive.
4. I/We do hereby submit our Bid, complete with all the required information as stipulated in your Bidding Documents.
5. I/We do hereby submit our Quotation as per requirements along with the following enclosures:
 - (i) Authorization Letter / MoU from the Company
 - (ii) Enlistment Order/Certificate issued by PHE Department
 - (iii) Any other relevant Documents.

Signature :

Name : (.....)

Title & Seal :

Date :

ANNEXURE-II

FORM OF PRICE BID SUBMISSION
(Quotation No. 1 of 2026 – 2027, Dated 13th July 2026)
(Aizawl Water Transmission Division, PHED)

To,

The Executive Engineer PHED
Aizawl Water Transmission Division,
Aizawl: Mizoram

Sir,

I/We, the undersigned, hereby submit price bid as follows:

COST BREAKUP FOR SITC OF 125 KVA SILENT DG SET AT GAWSS, PHASE-I,
PHED, MAUBAWK, AIZAWL

Sl No	Description of Item	Quantity	Rate in figure (Rs.)	Rate in words (Rs.)
1	Supply of 125 kVA Silent Diesel Generator Set complete with Control Panel, Acoustic Enclosure and all allied accessories.	1 complete set		
2	Transportation and transit insurance.	1 Job		
3	Installation, Testing & Commissioning of 125 kVA Silent Diesel Generator Set complete with Control Panel, Acoustic Enclosure, foundation preparation, exhaust piping, cabling, earthing, loading and unloading with all allied accessories.	1 Job		
	Grand Total:			

Signature :

Name : (.....)

Title & Seal :

Date :

ANNEXURE-III

TECHNICAL BID FORM

NIQ Number and Date:

Name of concerned Divisional Office:

(To be filled by Bidder)

1	Bidder's Name (firm/company Name) and Address	
2	Company Registration / Shop Act License No. and Validity	
3	Valid Dealership Certificate from OEM or OEM in one brand only is available and copy enclosed (Yes / No) <i>(Note: The Bidder must desirably have five years dealership)</i>	
4	Valid Certificate showing enlistment of firm in the department	
5	Organizational Capability (staff strength) <i>No. of Engineers ...</i> <i>No. of Supervisors ---</i> <i>No of Technicians...</i> <i>Quality Engineers ...</i>	
6	Provide details of 125 KVA and above capacity of satisfactory installations/commissioning completed within the past few years of similar nature, if any as per Form-I. Client Certificate to be attached for all the works.	(Provided / Not Available)
7	Details of on-going works for SITC of Diesel Generator Set of 125 KVA and/or above capacity of, if any as per Form-II. Client Certificate to be attached for all the works.	(Provided / Not Available)
8	Whether relevant documents from the manufacturer such as technical data, literature, drawings etc. are enclosed or not.	
9	List along with details of any arbitration cases / legal disputes on Current/ previous projects – (Mention name of project, reason for dispute, party filing the suit and its current status)	
10	Address of closest DG Set Service Centre from the destined installation site.	

Notes:

The bidder/quotationer has to fill/complete the technical bid form in all respects. Every statement made in the technical bid format should be supported by documentary proof for consideration and all pages of the tender should be verified and signed by the authorized person in this behalf. Otherwise, the tender is liable to be rejected.

DATA SHEET FOR D.G. SETS (To be filled by the Bidder along with the bid)

1. Name of Manufacturer:
2. Engine Make & Model Name/ No.:
3. Engine Type:
4. Engine BHP:
5. RPM:
6. Nos. of Cylinder:
7. Specific Fuel Consumption at 100% Load Litre/Hr.:
8. Fuel consumption at 75 % load (Litre /Hr):
9. Fuel consumption at 100% load (Litre /Hr):
10. Lube Oil Consumption @ % of fuel consumption:
11. Lube oil change period in DG running hours or minimum period in months:
12. Lube Oil Sump Capacity (Max) in Litre (High– Low Level):
13. Total Lubrication System Lube Oil Capacity in Litres:
14. Total Coolant capacity in Litres:
15. Type of Cooling:
16. Type of Starting:
17. Type of Governor, Make & Model Number:
18. Alternator Make:
19. Alternator Model Name/Number:
20. Type of Enclosure:
21. Enclosure IP Rating:
22. Alternator KW Rating:
23. Alternator KVA Rating:
24. Class of Insulation:
25. 24. Over all Dimension of Generator Set in mm (LxWxH) :
26. 25. Overall Generator Set Weight (in Kgs) :
27. Battery Charger Type:
28. Battery Charger Make & Model Number/Name:
29. Battery Charger Ratings (Voltage & Current):
30. Batteries Make, Model & Ratings (Voltage & AH):
31. 30. Control Panel Type:
32. Warranty Period:
33. Warranty Cover:

Signature :

Name : (.....)

Title & Seal :

Date :

BID/RATE VALIDITY FORM

NIQ Number and Date:

Name of concerned Divisional Office:

I, the undersigned do hereby undertake that the Bid submitted by our Firm

M/S _____ [name and address of Bidder] is valid for a period

of _____ days and valid till _____

Signed by an Authorized Signatory of the firm: _____

Title of the Signatory _____

Name of Firm _____

Date _____

BID SECURING DECLARATION

NIQ Number and Date:

Name of concerned Divisional Office:

To,

The Sr. Executive Engineer,
Aizawl Water Transmission Division,
Public Health Engineering Department,
Maubawk, Aizawl, Mizoram

I/We, the undersigned, declare that:

1. I/We understand that bids must remain valid for one year from the date of opening.
2. I/We accept that if we withdraw or modify our bid during the period of validity.

the Department may suspend/debar us from participating in future tenders of the Department for a period deemed appropriate by the competent authority.

Name of Bidder:

Address:

Authorized Signatory:

Seal:

Date:

FORM - I

DETAILS OF WORKS OF SIMILAR NATURE (SITC OF 125 KVA & ABOVE RATINGS) AND MAGNITUDE CARRIED OUT BY THE BIDDER

(DETAILS OF PROJECTS SHALL BE FILLED IN AS PER REQUIREMENT WITH PROOF)

NAME OF THE BIDDER:

NIQ Number and Date:

Name of concerned Divisional Office:

Table:

Sl No	Installed D.G. Set Capacity in kVA	Name and address of the organization from whom the work was done.	Address where installation was done.	Date of commencement	Scope of work done.	Total cost of work done (Rs. in lakhs)	Date of completion
1	2	3	4	5	6	7	8

Place & Date:

Signature of Bidder

Note: - This is only a standard form. Details are to be furnished in this format. The work done certificates shall be attached in support of the works claimed in this form.

FORM - II

STATEMENT SHOWING ON-GOING WORK(S) OF SIMILAR NATURE (SITC OF 125 KVA AND ABOVE DG SET)

(DETAILS OF PROJECTS SHALL BE FILLED IN AS PER
REQUIREMENT WITH PROOF)

NAME OF THE BIDDER:

NIQ Number and Date:

Name of concerned Divisional Office:

Table:

Sl. No.	D.G. Set Capacity in kVA	Name and address of the organization from whom the work is carried out.	Address of installation.	Commencement date or proposed date of commencement	Scope of work.	Percentage of work done.	Total cost of work (Rs. in lakhs)
1	2	3	4	5	6	7	8

Place & Date:

Signature of Bidder

Note: - This is only a standard form. Details are to be furnished in this format. Supporting documents shall be attached.