



No.D-15015/1/2016-E-in-C/PHE/20
GOVERNMENT OF MIZORAM
OFFICE OF THE ENGINEER-IN-CHIEF:PHED
MIZORAM :: AIZAWL



Dated Aizawl, the 5th February, 2019.

CIRCULAR

This is for information to all concerned that the following rate of GI Pipe (Medium and Heavy Class) is hereby approved by the State Purchase Advisory Board (SPAB) with effect from 17.1.2019.

A. GI Pipes Medium Class with Approved Firms

Sl. No	Size (MM) (Diameter)	Rate (Rs.)	Firm
1	15mm	104.49	NEZONE
2	20mm	132.63	NEZONE
3	25mm	197.65	NEZONE
4	32mm	251.93	NEZONE
5	40mm	289.10	NEZONE
6	50mm	397.37	NEZONE
7	65mm	516.84	NEZONE
8	80mm	671.09	SPARK
9	100mm	979.95	SPARK
10	125mm	1,269.68	NEZONE
11	150mm	1,530.80	SPARK

B. GI Pipes Heavy Class with Approved Firms

Sl. No	Size (Diameter)	Rate (Rs.)	Firm
1	15mm	123.68	NEZONE
2	20mm	160.21	NEZONE
3	25mm	243.84	SPARK
4	32mm	314.34	NEZONE
5	40mm	361.18	SPARK
6	50mm	497.93	SPARK
7	65mm	634.62	SPARK
8	85mm	790.32	SPARK
9	100mm	1,143.45	SPARK
10	125mm	1,405.03	SPARK
11	150mm	1,687.72	SPARK

TERMS AND CONDITIONS


- 1) The approved rates are valid for 1 (one) year.
- 2) The approved rates are **FOR Aizawl inclusive of GST, insurance, loading and unloading.**
- 3) The rates are fixed, no claim for increase of rates is allowed under any circumstances.
- 4) All pipes shall have cast or stamped or legibly and indelibly painted the following appropriate marks :-
 - a) Manufacturer's Name & Trademark.
 - b) IS Code i.e. IS 1239 (Part – I) 2008.
 - c) Class of Pipes i.e. M of H for Medium or Heavy Class respectively.
- 5) The different classes of pipes shall be distinguished by 75mm colour bands which shall be applied as follows :-
 - a) Medium Class – Blue
 - b) Heavy - Red
- 6) Third Party inspection shall be arranged by the manufacturer at its own cost from anyone of the following agencies :-
 - a) DGS&D
 - b) RITES
- 7) 100% payment will be made after the specified materials are received in full & in good condition. If due to any reason, payment is not made in due time, no interest claim will be entertained by the Department.
- 8) Delivery of materials should be completed within 60 days of issue of written order.

Sd/-LALMUANZOVA
Engineer-in-Chief : PHED
Mizoram : Aizawl

Memo No. D-15015/1/2016-E-in-C/PHE/20 'A' : Dated Aizawl, the 5th Feb, 2019.

Copy to :-

- 1) Chief Engineer, PHED, Zone – I & Zone – II for information and necessary action alongwith Minutes of Meeting of SPAB.
- 2) All Superintending Engineer under PHED for information and necessary action.
- 3) All Executive Engineer under PHED for information and necessary action.
- 4) All Sub-Divisional Officer under PHED for information and necessary action.
- 5) Approved Rate File.


Engineer-in-Chief : PHED
Mizoram : Aizawl