



No.M-11011/2/2016-E-in-C/PHE/83
GOVERNMENT OF MIZORAM
OFFICE OF THE ENGINEER-IN-CHIEF : PHED
MIZORAM : AIZAWL



Dated Aizawl, the 16th November, 2020.

NOTICE INVITING QUOTATION NO. 2 of 2020-2021

Sealed quotation is invited in two bid system, Technical Bid & Price/Commercial bid by undersigned from the manufacturers for fixation of rates of under mentioned materials. Quotations will be received upto 16.12.2020 Noon and will be opened on the same day at 2:00 PM at the Office chamber of Engineer-in-Chief, PHE Department.

Sl. No.	Description of materials	Size (mm)	Date & Time of Issue of tender	Cost of tender paper
1	Supply of different diameter of Galvanised Mildsteel Pipes, conforming to IS-1239 (Part-I) 2004 & IS-1239 (Pt-II), 2011, Class Medium & Heavy, screwed & Socketed of random length 4m to 7m, socket on one end, the other end protected with plastic thread protector, electric resistance welded or high frequency induction welded & pipe thread conforming to IS-554:1999.	15mm 20mm 25mm 32mm 40mm 50mm 65mm 80mm 100mm 125mm 150mm	10 am to 2 pm in all working days.	Rs. 500/-

The Quotation documents and other relevant particular terms & conditions may be seen by the intending quotationers during office hours in the office of Engineer-in-Chief, PHED, Aizawl, Mizoram and the same can be downloaded from PHED website at phed.mizoram.gov.in

TERMS & CONDITIONS

- 1) Quotation paper will be issued only to bonafide manufacturer of G.I Pipes.
- 2) Manufacturers should produce valid BIS License as on date of NIT.
- 3) Quotation should be submitted in two sealed covers. The first cover shall contain the documents relating to eligibility criteria and the envelope should super scribe as TECHNICAL BID. The second sealed cover shall contain price bid and to be super scribed as PRICE BID. The technical bid will be opened first in presence of all participating quotationers and if the technical bid qualifies, then only price bid will be opened. Otherwise the tender will be declared non-responsive/informal. The two sealed Covers are to be submitted in a large sealed cover to be superscripted Quotation No, Name of the Quotation and the date of opening.

- 4) The rates will be F.O.R Aizawl inclusive of all kinds of taxes, duties, insurance, loading, unloading etc. Quotationer must quote the net Price both in words as well in figures. Any over writing/cutting etc render the tender invalid.
- 5) Total price should indicate the breakup of statutory payments (like Excise Duty, sales Tax or any other Govt. taxes) either in percentage or lump sum on the quoted price. Price quoted shall remain valid for the full financial year/365 days from the date of opening of quotation whichever is later.
- 6) All documents are to be submitted with quotation duly authenticated.
- 7) The quotation received after the due date & time of opening shall not be accepted.
- 8) If the Office is closed on the stipulated date and time due to some unforeseen reason, quotation will be received up to and open in the next working day at the same place and time.
- 9) Quotation paper must be duly filled in all columns of the tender documents. No over writing will be allowed.
- 10) Manufacturers should have experience in manufacturing of G.I pipes and as per IS specification of diameter varying from 15mm of medium and heavy class and above for at least 5 years and the product should have given satisfactory performance for at least 5 years.
- 11) Manufacturers (Quotationers) should produce valid PAN no., Tax clearance Certificate/Partnership deed.
- 12) Each & every page of NIT must be signed by the Quotationer.
- 13) Incomplete quotation will not be accepted.
- 14) All pipes shall have as Cast or Stamped or legibly and indelibly painted on with the following appropriate mark:
 - a) Manufacturer name or Trade Mark
 - b) I.S no that is, IS 1239 (part-I) : 2004
 - c) Class of pipes, that is M or H for Medium or Heavy class.
- 15) The different classes of Pipes shall be distinguish by 75mm colour bands, which shall be applied as follows before the tubes leave the manufacture's work:
 - 1) Medium class- Blue
 - 2) Heavy class- Red
- 16) The zinc coating on the pipes shall be in accordance with IS 4736. (360g per square meter).

- 17) Each pipe shall be tested for leak tightness as in – process test at manufacturer's work by Hydrostatic test. The Hydrostatic test shall be carried out at a Pressure of 5MPa & the same should be maintained for at least 3 second & shall not show any leakage in the pipe. The authentic Hydrostatic test certificate carried out must be produced at the time of submission of quotation and supply of materials. Quality control authority certificate may be attached.
- 18) The thickness, dimension, nominal mass and maximum permissible pressure of pipes should be maintained as per table 4, table 5 and table 6 of IS 1239 (Part-I) : 2004. Tolerance shall be permitted on the Pipes & Sockets as per IS 1239 (part-I) : 2004.
- 19) The Pipes should be socketed at one end and the other end should be protected with Plastic ring protector. Socket is to be fitted so tightly to pipe end that it should not fall down during handling or transit. The socket so fitted must be as per IS-1239 (part-I) 2004 is respect of OD and length.
- 20) All pipes shall be clearly finished & reasonably free from injurious defects. The ends shall be free from sharp edges burrs of the pipe. The pipes shall be reasonably straight.
- 21) No escalation/discount will be entertained afterwards during the validity.
- 22) No conditional offer will be accepted.
- 23) The current Sales Tax Clearance certificate or Latest copy of Tax Return must be attached with the technical bid.
- 24) The Quotationer can remain present himself or his authorize representative at the time of opening of quotation.
- 25) All disputes are subject to the jurisdiction of the Courts at Aizawl.
- 26) This must be completed within the stipulated time as will be mentioned in the order, failing which liquidated damage shall be applicable.
- 27) The quotation will be rejected straightaway without assigning any reason if the manufacturer involves in any criminal case, declared black listed by any Govt/Semi Govt. department/agencies etc.
- 28) PHE Department does not bind itself to accept the lowest or any quotation and reserves the right to reject in part or in full or all tenders received.
- 29) PHED reserves the right to postpone/cancel the quotation without giving any reason.
- 30) Way bill for the importing of materials from other State should be arranged by the manufacturer.

- 31) In order to ensure quality, third party inspection shall be arranged by the manufacturer at its own cost from any one of the following agencies:-

(a) DGS&D (b) RITES

The materials will be accepted only on production of satisfactory test certificate issued by the above agencies.

NOTE:

(A) Documents required to be attached with Technical Bid in the following order :-

- 1) Sales Tax Registration Certificate & valid B.I.S License.
- 2) Latest Sales Tax Clearance Certificate / Latest Return.
- 3) Technical specification of the product offered along with literature/brochure.
- 4) Copy of terms and conditions duly signed with seal of the firm, in token of acceptance of terms and conditions.
- 5) All the firm participate in the quotation must submit a list of their owners/partners etc. and a Certificate to the effect that the firm is neither blacklisted by any Govt. Department nor any Criminal Case is registered against the firm or its owner or partners anywhere in India.
- 6) All other supporting documents mentioned in the term & condition as required in the quotation shall be attached.
- 7) Hydrostatic test certificate along with quality control authority certificate must be attached.

(B) Documents required to be attached with Commercial/Price Bid in the following order:-


- 1) Details of Rates of each items quoted by the quotationers shall be submitted in the tender documents prescribed proforma, in words and in figure. The cutting & over-writing not valid. The option in the rates will not be entertained.
- 2) Vogue offers like "Duties as applicable" shall not be considered.

(C.LALREMSIAMA)
Engineer-in-Chief : PHED
Mizoram : Aizawl

Memo No.M-11011/2/2016-E-in-C/PHE/83 'A' : Dated Aizawl, the 16th November, 2020.

Copy to:-

- 1) P.A to Hon'ble Minister, PHED etc for favour of kind information.
- 2) The Secretary to the Govt. of Mizoram, PHED for favour of kind information.
- 3) The Chief Engineer, Zone-I / Zone-II & Director, WSSO PHED for information.
- 4) All Superintending Engineers under PHED for information.
- 5) All Executive Engineers under PHED for information.
- 6) Director, I&PR, Govt. of Mizoram for favour of kind information and necessary action with a request to publish in 3(three) local newspaper and 2 (two) National Daily Newspaper in 3 (three) consecutive issue, samples for Press Notification is enclosed herewith.
- 7) The System Analyst, PHED for displaying on the Department Website.
- 8) Office Notice Board.


Engineer-in-Chief : PHED
Mizoram : Aizawl